Government of Andhra Pradesh

Water Testing Laboratory,
Rural Water Supply & Sanitation Department
O/o Deputy Executive Engineer,

TEST REPORT ON CHEMICAL ANALYSIS OF WATER(DRINKING)

General physical Chemical Parameter

Name and address of Department officials : Gurajada English Medium School Vizianagaram

Test Report ID No : 1
Description of the test items: Water Sample
Date of Collection : 28.09.2026 **Date of issue : 29.09.2026**

Sl.No.	Physcio-Chemical Parameters	Units	As per IS (10500 - 2012)		Name of the location	Sample Result
			Requirement (Acceptable Limit)	Permissible Limit (in the absence of alternative source)		
1	Turbidity	NTU	0	5		0
2	pH		6.5-8.5	No relaxation		7.43
3	Electrical Conductivity	micromhos/cm	-	-		113
4	Total Dissloved Solids	mg/lit	500	2000		79
5	Total Alkalinity as $CaCO_3$	mg/lit	200	600		44
6	Total Hardness as $CaCO_3$	mg/lit	200	600		36
7	Calcium as Ca++	mg/lit	75	200	SCHOOL	6.4
8	Magnesium as Mg++	mg/lit	30	100		4.8
9	Flouride as F^-	mg/lit	1.0	1.5		0.06
10	Chloride as Cl^-	mg/lit	250	1000		26
11	Nitrate as $NO3^-$	mg/lit	45	No relaxation		4.9
12	Sulphate as SO_4^-	mg/lit	200	400		0
13	Iron as Fe	mg/lit	0.3	1.0		0.02

REMARKS :Above sample is Chemically Satisfactory for drinking purpose.

R. Naidu 29/9/26
Lab Chemist
W.Q.M.Lab,
Sabbavaram

29/09/26
Assistant Exe Engineer,
RWS&S Sub Division,
Sabbavaram
Asst Engineer
R.W.S. & S Sabbavaram

MANAGER
MANAGER
Gurajada English Medium School
Cantonment, Vizianagaram.

PRINCIPAL
PRINCIPAL
Gurajada English Medium School
Cantonment, Vizianagaram.

Governament of Andhra Pradesh

Water Testing Laboratory,
Sabbavaram
Rural Water Supply & Sanitation Department
O/o Deputy Executive Engineer,
RWS & S Sub-Division, Sabbavaram

TEST REPORT ON BACTERILOGICAL ANALYSIS OF WATER(DRINKING)

S.No	Date of collection	Name and address of Department officials	Name of the Location	Total Coliform bacteria	E.Coli/100ml	Remarks
1	28.09.2026	Gurajada English Medium School Vizianagaram	School	0	0	BACTERILOGICALLY SAFE

REMARKS : Above sample are Bacterillogically Safe for drinking purpose.

Micorbiologist, 29/09/26
W.Q.M.Lab,
Sabbavaram

Assistant Exe Engineer, 29/09/26
RWS&S Sub Division,
Sabbavaram
Asst Engineer
R.W.S. & S. Sabbavaram

MANAGER

MANAGER
Gurajada English Medium School
Cantonment, Vizianagaram.

PRINCIPAL

PRINCIPAL
Gurajada English Medium School
Cantonment, Vizianagaram.

Roc.No.1015/2023-F3. Municipal Corporation, Vizianagaram.
Dt:29.06.2026.

SANITARY CERTIFICATE

This is to certify that, Sanitary certificate has been issued to the Director **GURAJADA ENGLISH MEDIUM SCHOOL, Cantonment, Vizianagaram-535003** duly fulfillment of following conditions and the certificate is valid for a period of one year with affect from 29.06.2026.

This certificate is issued subject to the following conditions:

1. First aid box and fire safety cylinders should be maintained in the School building premises.
2. Sufficient number of urinals and latrines must be provided as per the public health act. Norms to the students and the staff.
3. Toilets must be maintained kept neat and clean in every time.
4. Protected water should be supplied to the students for drinking purpose.
5. Properly ventilators and lighting should be provided.
6. Waiting hall must be providing for students.
7. The primes should always maintain clean and tidy.
8. Three dust bins must be provided, Dry waste, wet waste and third one for Hazard waste.
9. Sufficient plantations should be maintained around the campus.
10. Sufficient parking place should be provided for students vehicles.
11. Rain water harvesting structure should be provided at the campus.
12. Spittoons box must be provided in school premises.
13. Sufficient Fans/Ac provided as per student strength in the class room.

15/7/26

Municipal Health Officer,
Vizianagaram Municipal Corporation.

To,
The Director
GURAJADA ENGLISH MEDIUM SCHOOL,
Cantonment,
Vizianagaram-535003,
Ph:9440193517.

15/7/26

MANAGER
Gurajada English Medium School
Cantonment, Vizianagaram.

PRINCIPAL
Gurajada English Medium School
Cantonment, Vizianagaram.