## Government of Andhra Pradesh

## A.P. State Disaster Response and Fire Services Department

# Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire Officer
Andhra Pradesh, Vizianagaram

To:
The District Educational officer,
Vizianagaram.

File No: 33008/VZM/DFO/2026, Date:08/07/2026
Occupancy NOC RC Number: 470/DFO/VZM/2013

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **Gurajada E.M. School, represented by Malla Swarupa, D.No.1-23-1, Contonment, Vizianagaram** - Regarding.

Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated 02-05-2023.
3. This Office NOC for Occupancy Rc No. 470/DFO/VZM/2013, Dt.14/05/2013
4. Renewal NOC For Occupancy 470/DFO/VZM/2013, Dt.06/05/2019
5. Online Application for Renewal NOC of Malla Swarupa, D.No.1-23-1, Contonment, Vizianagaram - Inspection report called for Regarding.
6. Online Inspection Report submitted by Officers of this Department on 08-07-2026.

-- x --

The Management of Gurajada School, represented by Malla Swarupa, D.No.1-23-1, Contonment, Vizianagaram has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.14000/- vide challan No. 11107016142026, Dated 20/06/2026 at SBI, Vizianagaram.

## Gurajada E.M.School

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Malla Swarupa D.No.1-23-1, Contonment, Vizianagaram**, subject to the following conditions.

| Sl | As Builder | As Occupant | As Security Personnel |
|---|---|---|---|
| 1 | All the fire protection arrangements shall be maintained in good condition as seen during inspection. | All the escape/exit routes shall not be kept locked/blocked or encroached | All the occupants must know the correct method of operation of the fire fighting system installed. |
| 2 | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management. | All occupants shall be trained to operate the fire safety equipments during emergency. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. |
| 3 | Addition / alteration, if any in the building may be verified by building authority. | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months. | All security personnel shall be trained to operate the fire safety equipments during emergency. |
| 4 | This is Only for Fire Safety Point of View. | Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows. |

MANAGER
Gurajada English Medium School
Cantonment, Vizianagaram

PRINCIPAL
Gurajada English Medium School
Cantonment, Vizianagaram

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 08/07/2026 to 07/07/2027.
5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

| Challan Number | Challan Date | Challan Amount |
|---|---|---|
| 11107016142026 | 2026-06-20 | 14000 |

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

1.As per the remarks/report of the Inspecting Authority (FSIO, Vizianagaram), the Renewal No Objection Certificate is hereby issued.
2.The management shall ensure that all fire-fighting equipment installed in the premises is maintained in good working condition at all times. Further, fire mock drills shall be conducted at regular intervals to ensure the preparedness of the occupants in the event of a fire emergency.
3.This Renewal No Objection Certificate is liable to be cancelled if any deviations, violations, or non-compliance with the prescribed conditions or fire safety requirements are noticed at any stage in the future.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షితమైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై సన్నద్ధంగా ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."

DIGI VERIFIED

Your Sincerely,

8/7/26

District Disaster Response & Fire Officer,
Vizianagaram District

***In case of emergency, please call 101 or 08922276101 or 9963729543***

Copy to Management Malla Swarupa, Gurajada School, D.No.1-23-1, Contonment, Vizianagaram
Copy to Assistant District Fire Officer Concerned
Copy to Station Fire Officer Concerned

MANAGER
Gurajada English Medium School
Cantonment, Vizianagaram.

M. Swarupa
PRINCIPAL
Gurajada English Medium School
Cantonment, Vizianagaram.